

**Evacuation plan MDU**

Side: 1 av 1

Utarbeidet av: Frøydis Kilmer, Tone  
Fadum, Thanh Tham Pham og Noline  
Kongsten.

Godkjent av: Espen Engh

Godkjeningsdato: 11.09.2020  
Utgave: V1

This procedure describes the evacuation plan in case of fire/fire alarm for all personnel in the MDU at KPM. The purpose of the procedure is to ensure the safety of people and to prevent GMO from escaping into the wild.

The head of KPM is responsible for the training of all personnel at KPM and for documenting that training has been carried out. The group leaders are responsible for the training of their respective employees. All visitors are responsible for familiarizing themselves with the emergency exits. Note that in the animal rooms and laboratories there will only be a visual warning, not a sound warning.

**In case of fire / fire alarm**

The following instructions are to be followed as long as long as doing so does not pose a threat to life and health:

1. Personnel may attempt to extinguish a fire with a water hose or CO<sub>2</sub> appliance.
2. If the fire cannot be extinguished, the nearest manual fire detector must be triggered.
3. Close any open doors and evacuate immediately! Call the fire department at 110.
4. Everyone must evacuate in case of a fire alarm and everyone is responsible for his/her own evacuation.
5. The instruction is to be followed as long as safety is maintained.
6. Any open cages containing animals must be closed before evacuation.
7. Any experiments must cease immediately. The termination of animals must be considered. NB! Animals in anesthesia must not be able to wake up and escape from the facility.
8. If any gases, like propane or oxygen is in use, close the outlet.
9. Employees evacuate or go to the fire panel in DU-001c to see where the alarm is triggered.
10. The emergency switch for the air shower must be activated during evacuation.
11. The "floor contact person" goes to the fire panel and reads off the affected room number. The alarm site must be investigated if the alarm has been triggered in the MDU.
12. Employees at KPM encourage anyone in the immediate vicinity to evacuate.
13. The meeting point outside is behind the wall by the containers at the loading dock.
14. Personnel are not allowed to re-enter the building until instructed to do so over the loudspeaker.
15. The "floor contact person" stays behind to clarify the situation with the Estate department.

**Evacuation****Option 1:** Evacuation via locker rooms**Option 2:** Evacuation via marked emergency exit in the dirty corridor, DU-025 (by PET/CT )**Option 3:** Evacuation via marked emergency exit in the dirty corridor, DU-001c (reception)**Option 4:** Evacuation via marked emergency exit in the clean corridor, DU- 010. NB! Only in case of visual fire and / or smoke development