

Report 2- 2017 LAMU- NCMM, Friday , June 16.06.17 at 09.30– 11.30

Present: Siri Høgseth, Gladys Tjørhom, Mari Nyquist-Andersen , Kirsti Elisabeth Præsteng and Liv Bjørland.

Not present: Camila Esguerra

Item 1-2/17 Minutes from meeting **15.02.17** was approved

Item 2-2/17 Short briefings.

- Result from the GMO-inspection: The business operates in accordance with current regulations. Good understanding of risk assessment. Good understanding of security level. All interviewees explained how routines, key people and how a case of risk assessment was handled. The infrastructure was suitable. Deviation: filter in drain in fishing facility had too large mesh size. The deviation must be corrected within 1 July
- Discharged chemicals and relabeling. NCMM has discharged all chemicals reported to the inspection 2016 and even a lot more, but we have not finished the relabeling to CLP for all old chemicals . However we have established the system for how to do it.
- Check-up of hoods. One hood in 52055A was repaired because of a disturbing sound. All hoods were accepted. There was established a huge leakage in the ventilation system for incoming air. OsloTech took care of the repair.
- More Information about the defibrillators. UiO has made a procedure and informed about www.113.no. Unfortunately none of the defibrillators at UiO are reported to the web portal.

Item 3-2/17 The form for checkups of connected gas-tubings

- The form was approved. *Liv sends out the form to all principal engineers and also other people working with gas supply.*

Item 4-2/17 The CIM-deviations.

- LAMU went through the deviation reports concerning fire alarms and emergency showers. *1) Mark the light and buzzer fire-alarms in the cold rooms and the fish facility. 2) Send out information to all employees. 3) Include the information in the fire safety round.*

Item 5-2/17 Safety inspection 2017.

- If possible our Lamu-members need to send in a proposal before next meeting.

Item 6-2/17 Fire warden /etasjeansvarlig

- NCMM need to replace one of the fire-watch at D3. *Do inquirers to suggested person (J.B.).*

Item 7-2/17 Miscellaneous. The safety deputies directed the attention towards handling of conflicts and questioned an ARK-investigation. Siri will contact Elisabeth Olsen concerning: 1) next time for an Ark-investigation at the Medical Faculty. 2) Objections about implementing ARK as a tool for conflict management. 3) Is it possible to get help to carry out an investigation?

Item 8-2/17 The 3rd LAMU-meeting 2017

Suggestion: Doodle a time in the middle of September.

Attachments for the meeting

- Item 1 LAMU-report 1 - 15.02.17
- Item 3 Form for the checkups
- Item 4 Deviation reports

04.08.17 Liv Bjørland